

Approval Number 250355076
Test Report: J-00500447



9th April 2025

Element Boya SAN. VE TIC. A.S
Birlik OSB 6,
Sokak No. 5,
Tuzla,
Istanbul 34953
Turkey

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS- FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

'ELM EPX 13'. Factory applied, blue coloured epoxy coating.

Apply as per manufacturer's instructions to end users reference no. 'ELM/2019/10/001' dated '23/08/2024'. Cure for 10 minutes@130°C. For use with water up to 85°C.

This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 250355076

APPROVAL HOLDER: ELEMENT BOYA SAN. VE TIC. A.S

The Scheme reserves the right to review approval.
Approval 250355076 is valid between March 2025 and March 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager